

## CERTIFICATE

### CONCERNING THE TYPE TEST OF ENERGY METERS

Manufacturer/Applicant : *Electro Industries  
U.S.A.*

Instrument : *Three-phase energy meter, class 0,2S*

types : *Nexus 1260, Nexus 1262, Nexus 1270,  
Nexus 1272 and Nexus 127X*

measurement range : *3 x 120/208 to 480/831 V\*  
5(20) A,  
50 or 60 Hz*

Period of investigation : *August and September 2002 and July 2004*

Results of the type test :


*The energy meter fulfils the requirements mentioned in:*

- *IEC 62053-22 (2003): "Electricity metering equipment (a.c.) - Static meters for active energy (classes 0,2 S and 0,5 S)", (requirements for indoor use)*

*The results of the type test are mentioned in KEMA report with reference number 2075360-QUA/CAL 04-1412.*

Arnhem, 28 July 2004

KEMA Quality B.V.



R.H. Garssen

Calibration Laboratory

\* *Limited testing at maximum voltage, see test report.*